







SITE HEALTH & SAFETY INSPECTION

Site:	Weatherark Royal Porcelain Works Worcester	By:	STEVE HARPER	Date:	Wednesday 28 th June 2017
OBSERVATIONS			CORRECTIVE ACTION		
1	The welfare facilities were being maintained in a clean and tidy condition.	Good to see. Operatives to be encouraged to respect the facilities provided.			
2	Demolition arisings were being segregated into waste streams for removal from site to appropriate waste facilities. 				
3	Within the structure there is a live substation which was insecure and access was readily available, leaving potential for unauthorised access. 	Site manager of 'Weatherark' was informed at the time of observation.			



SITE HEALTH & SAFETY INSPECTION

4	<p>Part of the brick wall surrounding the basement steps to one of the structures had been removed during demolition activities leaving potential for falls from height.</p> 	<p>The Kings Heath Demolition Supervisor was informed at the time of observation. Fencing was to be erected to prevent any potential of falls from height.</p>		
5	<p>During the site tour operatives were questioned about their tasks and were able to demonstrate that they had been fully briefed on the method statement and gave clear explanations of their individual roles on site.</p>	<p>Excellent</p>		
6	<p>PPE discipline on site overall is excellent, with operatives wearing the minimum mandatory site requirements.</p>	<p>Maintain standard.</p>		
7	<p>The general site tidiness and housekeeping observed during the tour was very good considering the demolition activities that were ongoing. Poor housekeeping is the biggest cause of trips and falls.</p>	<p>Operatives should be encouraged to maintain the current standard. Well done!</p>		
<p>Signed Inspector: </p>		<p>Signed Site:</p>	<p>Distribution:</p>	
<p>Notes:</p>		<p>Director:</p>	<p>PF & JS</p>	
		<p>Senior Site Manager:</p>	<p>Weatherark</p>	
		<p>File:</p>		
		<p>Inspection Number (on audit)</p>	<p>001/SH/17</p>	